

From: "O'Keefe, Jeff (CDPH-DDWEM)" <Jeff.Keefe@cdph.ca.gov>
To: Frederick Schauffler/R9/USEPA/US@EPA
Cc: "Orr, Shu-Fang (CDPH-DDWEM)" <Shu-Fang.Orr@cdph.ca.gov>, "Souza, Kurt (CDPH-DDWEM-DWFO)" <Kurt.Souza@cdph.ca.gov>
Date: 08/09/2011 05:39 PM
Subject: Omega ROD

Fred,

I received your voicemail question about what cleanup standard for Cr 6 should EPA use in the Omega ROD. That is a difficult question to answer since we have not yet proposed a MCL yet. I think it would be reasonable to use 5 ppb as a placeholder since we have confidence that the existing treatment technology is capable of removing to that level, with maybe another clause that it would be revised if a lower state or federal MCL is proposed or adopted.

Jeff O'Keefe

District Engineer
Metropolitan District
California Department of Public Health
Southern California Branch - Drinking Water Field Operations
500 N. Central Avenue, Suite 500
Glendale, CA 91203

Direct:: 818-551-2044
General: 818 551 2004
Fax:: 818 551-2054
email: jeff.okeefe@cdph.ca.gov